


เสาไฟฟ้า

เสาไฟฟ้าคอนกรีตอัดแรง



ELECTRIC POLE

SIZE (M.)	WEIGHT (KG.)	MOMENT (KG.-M.)	
		WORKING	ULTIMATE
8.00	525	760	2,280
9.00	625	1,070	3,210
12.00	1,300	2,550	7,650
12.20	2,040	5,900	11,800
14.00	2,000	3,590	10,770
14.30	3,160	9,000	18,000
16.00	2,700	5,300	15,900
22.00	6,000	18,000	36,000

เสาคอนสปีน



SPUN

SIZE (M.)	WEIGHT (KG.)	MOMENT (KG.-M.)	
		WORKING	ULTIMATE
0.10x0.10x2.50	60	265	795
0.10x0.10x3.20	80	265	795
0.12x0.12x2.00	65	450	1,350
0.12x0.12x2.50	80	500	1,500
0.12x0.12x3.00	95	390	1,170


เสาคานนั่งร้าน



BEAM

SIZE (M.)	WEIGHT (KG.)	MOMENT (KG.-M.)	
		WORKING	ULTIMATE
0.15x0.25x3.55	310	1,200	3,600
0.15x0.30x4.60	510	2,250	6,750
0.20x0.35x4.80	810	2,250	6,750

เสาคอนกรีต



STUB

SIZE (M.)	WEIGHT (KG.)	MOMENT (KG.-M.)		SPECIFICATION	
		WORKING	ULTIMATE	VENDOR LIST	CALCULATION SHEET
0.25x0.25x3.50-5.50	500-800	1,470	4,410	Cover Vendor-list / P 11-19	Stub 0.25x0.25x3.5-5.5 m.
0.30x0.30x4.50-6.50	900-1330	3,300	9,900	Cover Vendor-list / P 11-19	Stub 0.30x0.30x4.5-6.5 m.
0.35x0.35x4.50-6.50	1200-1790	4,700	14,100	Cover Vendor-list / P 12-19	Stub 0.35x0.35x4.5-6.5 m.
0.36x0.36x4.50-6.50	1400-2020	8,200	24,600	Cover Vendor-list / P 12-19/13-19	Stub 0.36x0.36x4.5-6.5 m.

เสาสมอบก



ANCHOR

SIZE	WEIGHT	MOMENT (KG.-M.)		SPECIFICATION	
(M.)	(KG.)	WORKING	ULTIMATE	VENDOR LIST	CALCULATION SHEET
0.55x0.55x15.00	110	-	-	Cover Vendor-list / P 19/19	ANCHOR 0.55x0.55x15.00